



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
202

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Janet Hasbargen to a Fire Certificate of Occupancy Correction Notice at 1391 HAZEL STREET NORTH.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1391 Hazel.appeal.10-13-11.pdf, 2. 1391 Hazel St N.Hasbargen Ltr 10-25-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of Janet Hasbargen to a Fire Certificate of Occupancy Correction Notice at 1391 HAZEL STREET NORTH.

Windows open to 23 inches instead of 24 inches.

October 5, 2011

Yes, 1 inch in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Janet Hasbargen to a Fire Certificate of Occupancy Correction Notice at 1391 NORTH HAZEL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.