



Legislation Details (With Text)

File #: RLH CO 11-8 **Version:** 2

Type: Resolution LH Correction Order (Code Enforcement Only) **Status:** Passed

In control: City Council

Final action: 8/3/2011

Title: Appeal of Heather Matias, on behalf of Selby-Dale Cooperative, to a Correction Notice-Complaint Inspection at 666 DAYTON AVENUE.

Sponsors: Melvin Carter III

Indexes: Correction Order, Ward - 1, Windows

Code sections:

Attachments: 1. 666 Dayton.appeal.6-22-11.pdf, 2. 666 Dayton Ave.Matias Ltr 7-12-11.pdf

Date	Ver.	Action By	Action	Result
8/12/2011	2	Mayor's Office	Signed	
8/3/2011	2	City Council	Adopted	Pass
7/12/2011	1	Legislative Hearings	Referred	

Appeal of Heather Matias, on behalf of Selby-Dale Cooperative, to a Correction Notice-Complaint Inspection at 666 DAYTON AVENUE.

Windows - Asking for a variance on windows in bedrooms. They are only 1-1/2" off required.

May 19, 2011

Yes, 2 inches in the opening height of the egress window in the 4 sleeping rooms listed in this set of Fire Inspection Orders.

No hearing necessary.

WHEREAS, in the matter of the appeal of Heather Matias, on behalf of Selby-Dale Cooperative, to a Correction Notice-Complaint Inspection at 666 DAYTON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all four sleeping rooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.