



Legislation Details (With Text)

File #: ALH 10-513 **Version:** 1
Type: Appeal-Legislative Hearing **Status:** Filed
In control: Legislative Hearings
Final action: 12/14/2010
Title: Appeal of Sergio Rodriguez to a Fire Inspection Correction Notice at 351 LAWSON AVENUE EAST.
Sponsors: Lee Helgen
Indexes: Fire C of O Letter, Ward - 5, Windows
Code sections:
Attachments: 1. 351 Lawson.appeal.12-14-10.pdf, 2. 351 Lawson Ave E.PC ltr.12-14-10.pdf

Date	Ver.	Action By	Action	Result
12/14/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Sergio Rodriguez to a Fire Inspection Correction Notice at 351 LAWSON AVENUE EAST.

Interior both units - MSFC 1026.1. Windows must be min. 5 square ft. glazed area with min. 24 " openable ht + 20" openable width.

Our double hung windows measured 19" openable ht. * 26" openable width.

Appeal because new windows and the width is bigger than the ht. required, and the bedrooms are close to the 2nd bedrooms that have required measurements on windows.

November 23, 2010

No hearing Necessary. Recommend grant of a variance.