



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
194

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 11/16/2011

**Title:** Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 1076 Conway.appeal.10-7-11.pdf, 2. 1076 Conway St.Mazzarra Ltr 10-20-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/18/2011	1	Legislative Hearings	Referred	

Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET.

Only egress windows - Height variance of 1", 23" height where 24" is required

October 10, 2011

WHEREAS, in the matter of Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress window in the upper unit northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.