

Legislation Details (With Text)

File #:	ALH	l 10-326	Version: 1			
Туре:	Appeal-Legislative Hearing			Status:	Filed	
				In control:	Legislative Hearings	
				Final action:	11/16/2010	
Title:	Appeal of Xai Thao to a Fire Certificate of Occupancy Correction Order at 219 WHITE BEAR AVENUE NORTH.					
Sponsors:	Kathy Lantry					
Indexes:	Fire C of O Letter, Ward - 7, Windows					
Code sections:						
Attachments:	1. 219 White Bear Ave N.Appeal.10-29-10.pdf, 2. 219 White Bear Ave N.Fire C of O Ltr.9-29-10, 3. 219 White Bear Ave N.PC ltr.11-9-10, 4. 219 White Bear Ave N.PC ltr.11-16-10.pdf					
Date	Ver.	Action By	,	Ac	tion	Result
11/16/2010	1	Legislativ	ve Hearings	Re	eferred Under Master Resolution	
11/9/2010	1	Legislativ	ve Hearings	La	id Over	

Appeal of Xai Thao to a Fire Certificate of Occupancy Correction Order at **219 WHITE BEAR AVENUE NORTH.**

Egress windows.

September 29, 2010

No hearing necessary.

For upper floor northwest and northeast bedrooms (double hung): recommend variance on egress window opening height of 4" in height.

For basement southeast and northwest bedrooms (double hung): recommend variance on egress window opening height of 8" in height. Also, recommend variance on maximum sill height of 2" if a step of standard size is installed permamently affixed to the wall and running the entire width of the window.

For basement west bedroom (double hung): recommend variance on egress window opening height of 8" in height. Also, recommend variance on maximum sill height of 2" if a step of standard size is installed permamently affixed to the wall and running the entire width of the window.