

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FCO 13- Version: 2

218

Type: Resolution LH Fire C of O OR Status:

Correction Order

In control: City Council

Passed

Final action: 9/18/2013

Title: Appeal of Doug Ouimet to a Correction Notice-Complaint Inspection at 1467 SEVENTH STREET

EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6

Code sections:

Attachments: 1. 1467 7th St E.appeal.8-23-13, 2. 1467 Seventh Se E.Ouimet Ltr 9-4-13

Date	Ver.	Action By	Action	Result
9/23/2013	2	Mayor's Office	Signed	
9/18/2013	2	City Council	Adopted	Pass
9/3/2013	1	Legislative Hearings	Referred	

Appeal of Doug Ouimet to a Correction Notice-Complaint Inspection at 1467 SEVENTH STREET EAST.

Inspector wants power turned on in a vacant apartment. Power is always turned off by XCEL between tenants. Power is not needed for smoke detectors or heat. Smoke detectors are battery only.

August 13, 2013

James Thomas

WHEREAS, in the matter of Appeal of Doug Ouimet to a Correction Notice-Complaint Inspection at 1467 SEVENTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.