

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: ALH 11-414 Version: 1

Type: Appeal-Legislative Hearing Status: Filed

In control: Legislative Hearings

Final action: 3/22/2011

Title: Appeal of Floyd Johnson to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1571

HAZELWOOD STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1571 Hazelwood.appeal.3-16-11.pdf, 2. 1571 Hazelwood St.Johnson Ltr 3-22-11.pdf

Date	Ver.	Action By	Action	Result
3/22/2011	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Floyd Johnson to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1571 HAZELWOOD STREET.

The reason for this appeal is to claim that the windows in the bedroom are too small. The opening size of the double hung windows are 35 inches wide and 20 inches high. The glazed area is 32 inches wide and 36 inches high, which equals 8 square feet.

The house was built in the 1950's. I don't think the windows should be required to meet new construction codes. I would recommend leaving it as is (grandfathered in). I would appreciate your agreement with my cause.

March 7, 2011

No hearing necessary. Recommend variance be granted on egress window dimensions.