



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
209

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 11/16/2011

Title: Appeal of Cal Xiong to a Fire Certificate of Occupancy Correction Notice at 1108 EDGERTON STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1108 Edgerton.appeal.11-14-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
11/1/2011	1	Legislative Hearings	Referred	

Appeal of Cal Xiong to a Fire Certificate of Occupancy Correction Notice at 1108 EDGERTON STREET.

#19 of Deficiency List. Window openings are a couple inches short of the minimum of 20".

September 14, 2011

Yes, 2 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Cal Xiong to a Fire Certificate of Occupancy Correction Notice at 1108 EDGERTON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of the egress windows in the southeast and southwest bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.