



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
103

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 8/17/2011

Title: Appeal of Howard Googins to an Egress Window Non-Compliance Determination at 834 PORTLAND AVENUE.

Sponsors: Melvin Carter III

Indexes: Ward - 1, Windows

Code sections:

Attachments: 1. 834 Portland.appeal.7-13-11.pdf

Date	Ver.	Action By	Action	Result
8/23/2011	2	Mayor's Office	Signed	
8/17/2011	2	City Council	Adopted	Pass
7/26/2011	1	Legislative Hearings	Referred	

Appeal of Howard Googins to an Egress Window Non-Compliance Determination at 834 PORTLAND AVENUE.

Requesting variance for egress contained in Items #3 and #6 in inspection report.

June 14, 2011

No hearing necessary. Grant a 6.5-inch variance on the first floor, two bedrooms windows; grant a 4.5-inch variance on 2nd floor front bedroom windows

WHEREAS, in the matter of the appeal of Howard Googins to an Egress Window Non-Compliance Determination at 834 PORTLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6.5-inch variance on the openable height of the egress windows in the first floor two bedrooms, and grant a 4.5-inch variance on the openable height of the egress window in the second floor front bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.