



Legislation Details (With Text)

File #: ALH 11-376 **Version:** 1
Type: Appeal-Legislative Hearing **Status:** Filed
In control: Legislative Hearings
Final action: 3/22/2011
Title: Appeal of Steven Johnson to a Fire Inspection Correction Notice at 983 JAMES AVENUE.
Sponsors: Dave Thune
Indexes: Fire C of O Letter, Ward - 2, Windows
Code sections:
Attachments: 1. 983 James.appeal.3-22-11.pdf, 2. 983 James Ave.Johnson Ltr 3-22-11.pdf

Date	Ver.	Action By	Action	Result
3/22/2011	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Steven Johnson to a Fire Inspection Correction Notice at 983 JAMES AVENUE.

Window is 5.2 sq ft glass needs to be 5.0 sq ft glass. Older style window odd dimensions!!!

February 22, 2011

No hearing necessary. Recommend variance on egress window dimensions.