



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
269

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 1/18/2012

Title: Appeal of Public Housing Agency of St. Paul (Tony Swanson) to a Fire Certificate of Occupancy Correction Notice at 1676 LUELLA STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1676 Luella.appeal.12-8-11.pdf, 2. 1676 Luella St N.PHA Ltr 12-20-11.pdf

Date	Ver.	Action By	Action	Result
4/18/2012	2	Mayor's Office	Signed	
1/24/2012	2	Mayor's Office	Signed	
1/18/2012	2	City Council	Adopted	Pass
12/20/2011	1	Legislative Hearings	Referred	

Appeal of Public Housing Agency of St. Paul (Tony Swanson) to a Fire Certificate of Occupancy Correction Notice at 1676 LUELLA STREET.

#2 All bedrooms - MSFC 1026.1 - Request variance on openable height.

November 9, 2011

James Thomas

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Public Housing Agency of St. Paul (Tony Swanson) to a Fire Certificate of Occupancy Correction Notice at 1676 LUELLA STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.