



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
49

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 5/18/2011

**Title:** Appeal of William B. Becker to a Fire Inspection Correction Notice at 2072 MOHAWK AVENUE.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 2072 Mohawk.appeal.3-29-11.pdf, 2. 2072 Mohawk Ave.Becker Ltr 4-12-11.pdf

Date	Ver.	Action By	Action	Result
4/2/2014	2	Mayor's Office	Signed	
5/18/2011	2	City Council	Adopted	
4/12/2011	1	Legislative Hearings	Referred	

Appeal of William B. Becker to a Fire Inspection Correction Notice at 2072 MOHAWK AVENUE.

Need variance for bedroom window. Has been inspected numerous times & has passed. Window is within inches one direction & over in other direction.

March 24, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of William B. Becker to a Fire Inspection Correction Notice at 2072 MOHAWK AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the upper unit southwest bedroom; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.