



## Legislation Details (With Text)

**File #:** RLH WP 11- 34 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 8/3/2011  
**Title:** Appeal of Emmanuel D'Huyvetter to an Egress Window Non-Compliance Determination at 1375 MARGARET STREET.  
**Sponsors:** Kathy Lantry  
**Indexes:** Ward - 7, Windows  
**Code sections:**  
**Attachments:** 1. 1375 Margaret.appeal.6-24-11.pdf

Date	Ver.	Action By	Action	Result
8/12/2011	2	Mayor's Office	Signed	
8/3/2011	2	City Council	Adopted	Pass
7/5/2011	1	Legislative Hearings	Referred	

Appeal of Emmanuel D'Huyvetter to an Egress Window Non-Compliance Determination at 1375 MARGARET STREET.

Only egress windows

June 24, 2011

Yes, 3 inches in the egress opening width. No hearing necessary.

WHEREAS, in the matter of the appeal of Emmanuel D'Huyvetter to an Egress Window Non-Compliance Determination at 1375 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; AND

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable width of two slider replacement egress bedroom windows measuring 39 inches high by 17 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.