



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-306

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 12/19/2012

Title: Appeal of Andrea Atkinson to a Correction Notice-Foster Care Inspection at 521 BRIMHALL STREET.

Sponsors: Chris Tolbert

Indexes: Fire C of O Letter, Ward - 3, Windows

Code sections:

Attachments: 1. 521 Brimhall St.appeal.11-13-12, 2. 521 Brimhall St.Atkinson Ltr 11-28-12

Date	Ver.	Action By	Action	Result
12/21/2012	2	Mayor's Office	Signed	
12/19/2012	2	City Council	Adopted	Pass
11/27/2012	1	Legislative Hearings	Referred	

Appeal of Andrea Atkinson to a Correction Notice-Foster Care Inspection at 521 BRIMHALL STREET.

Bedroom windows do not meet requirements for size due to age of the house.

October 22, 2012

James Perucca

Appellant said during phone conversation on 11-13-12, new windows were installed in August under permit.

Yes, recommend a variance of 2 inches egress opening height for the listed windows.
No hearing necessary.

WHEREAS, in the matter of the Appeal of Andrea Atkinson to a Correction Notice-Foster Care Inspection at 521 BRIMHALL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.