



Legislation Details (With Text)

File #: RLH FCO 14- **Version:** 2
33

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 3/19/2014

Title: Appeal of Charles Kosse to a Fire Inspection Correction Notice at 310 SHERMAN STREET.

Sponsors: Dave Thune

Indexes: Fire C of O Letter, Ward - 2

Code sections:

Attachments: 1. 310 ShermanSt.appeal.2-13-14, 2. 310 Sherman St.Photos Submitted by Owner.2-25-14, 3. 310 Sherman St.Kosse Ltr.2-27-14

Date	Ver.	Action By	Action	Result
3/21/2014	2	Mayor's Office	Signed	
3/19/2014	2	City Council	Adopted	Pass
2/25/2014	1	Legislative Hearings	Referred	

Appeal of Charles Kosse to a Fire Inspection Correction Notice at 310 SHERMAN STREET.

I am appealing numbers 2 and 3 on the deficiency list. I would prefer the key box be located on the employee entrance (rear of building adjacent to our parking lot). I would also prefer to retain the interior surface bolts on our front door for security reasons.

February 6, 2014

Sebastian Migdal

Photos would be helpful, if possible with schedule.

WHEREAS, in the matter of Appeal of Charles Kosse to a Fire Inspection Correction Notice at 310 SHERMAN STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant until April 18, 2014 for owner to further discuss options with locksmith relating to the bolt locks in the main exit and deny the appeal on the lock box issue; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.