



Legislation Details (With Text)

File #: ALH 11-416 **Version:** 1
Type: Appeal-Legislative Hearing **Status:** Filed
In control: Legislative Hearings
Final action: 3/22/2011
Title: Appeal of Kibrom Haile to a Fire Inspection Correction Notice at 235 ANN STREET.
Sponsors: Dave Thune
Indexes: Fire C of O Letter, Ward - 2, Windows
Code sections:
Attachments: 1. 235 Ann.appeal.3-22-11.pdf, 2. 235 Ann St.Haile Ltr 3-22-11.pdf

Date	Ver.	Action By	Action	Result
3/22/2011	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Kibrom Haile to a Fire Inspection Correction Notice at 235 ANN STREET.

egress windows, double hung opening 20" h by 26" w. Glazed area 41" h by 23.5" w.

January 24, 2011

No hearing necessary. Recommend variance on egress window opening dimensions.