



Legislation Details (With Text)

File #: RLH WP 12- 10 **Version:** 3
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 2/15/2012
Title: Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 1699 Case.appeal.1-17-12.pdf, 2. 1699 Case Ave.Public Health REVISED Ltr.1-26-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 2/21/2012 | 3 | Mayor's Office | Signed | |
| 2/15/2012 | 3 | City Council | Adopted | Pass |
| 1/24/2012 | 2 | Legislative Hearings | Referred | |

Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE.

(Windows)

January 16, 2012

(none listed)

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Saint Paul Ramsey County Department of Public Health, to two Egress Window Non-Compliance Determinations at 1699 CASE AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.3 inches wide, and grant a 4-inch variance on the openable height of one double hung replacement egress bedroom window measuring 20 inches high by 26.8 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.