



## Legislation Details (With Text)

**File #:** RLH FOW 12-237 **Version:** 2

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 7/18/2012

**Title:** Appeal of Michael Doody to a Fire Certificate of Occupancy Correction Notice (windows only) at 1223 WELLESLEY AVENUE.

**Sponsors:** Chris Tolbert

**Indexes:** Fire C of O Letter, Ward - 3, Windows

**Code sections:**

**Attachments:** 1. 1223 Wellesley.appeal.6-6-12, 2. 1223 Wellesley Ave.Doody Ltr 6-21-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/19/2012	1	Legislative Hearings	Referred	

Appeal of Michael Doody to a Fire Certificate of Occupancy Correction Notice (windows only) at 1223 WELLESLEY AVENUE.

Windows in north and south bedrooms, #6

May 8, 2012

Rick Gavin

No hearing necessary.

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the Appeal of Michael Doody to a Fire Certificate of Occupancy Correction Notice at 1223 WELLESLEY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in the north bedroom, and grant a 3-inch variance on the openable height of the egress window in the south bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.