



Legislation Details (With Text)

File #: RLH FCO 11- **Version:** 2
325

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 12/7/2011

Title: Appeal of Thomas L. Corrigan to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1689 STILLWATER AVENUE.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1689 Stillwater.appeal.8-15-11.pdf, 2. 1689 Stillwater.Photo.9-6-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
10/4/2011	1	Legislative Hearings	Referred	
9/6/2011	1	Legislative Hearings		

Appeal of Thomas L. Corrigan to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1689 STILLWATER AVENUE.

Windows open 23 1/2"
Area behind garage is unpaved city alley.

June 13, 2011

Yes, 2 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Thomas L. Corrigan to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1689 STILLWATER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the bedroom egress windows; deny the appeal on the alley issue and grant an extension to July 1, 2012 to come into compliance through the use of gravel on that portion of the unimproved right -of-way abutting the garage which is currently used as parking (see attached photos); Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.