



## Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-249

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 7/18/2012

**Title:** Appeal of Mai Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 1751 STILLWATER AVENUE.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1751 Stillwater Ave.appeal.6-14-12.pdf, 2. 1751 Stillwater Ave.Yang ltr 6-27-12.pdf

Date	Ver.	Action By	Action	Result
7/24/2012	2	Mayor's Office	Signed	
7/18/2012	2	City Council	Adopted	Pass
6/26/2012	1	Legislative Hearings	Referred	

Appeal of Mai Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 1751 STILLWATER AVENUE.

Provide and maintain an approved escape window from each sleeping room.

June 7, 2012

James Thomas

No hearing necessary.

Yes, 8 inches egress opening height.

WHEREAS, in the matter of the Appeal of Mai Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 1751 STILLWATER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant an 8-inch variance on the openable height of the egress bedroom window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.