



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
54

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 6/15/2011

**Title:** Appeal of Edward Anderson to a Fire Certificate of Occupancy Correction Notice at 979 MARSHALL AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 979 Marshall.appeal.5-12-11.pdf

Date	Ver.	Action By	Action	Result
6/20/2011	2	Mayor's Office	Signed	
6/15/2011	2	City Council	Adopted	Pass
5/24/2011	1	Legislative Hearings	Referred	

Appeal of Edward Anderson to a Fire Certificate of Occupancy Correction Notice at 979 MARSHALL AVENUE.

Only Egress Windows

April 18, 2011

Yes. 3 inches in openable height of window in Unit A front and rear bedrooms, and Unit B rear bedroom.

WHEREAS, in the matter of the Appeal of Edward Anderson to a Fire Certificate of Occupancy Correction Notice at 979 MARSHALL AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in Unit A, front and rear bedrooms and Unit B, rear bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.