



Legislation Details (With Text)

File #: RLH WP 12- 62 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/3/2012
Title: Appeal of Greg Fry to an Egress Window Non-Compliance Determination at 2209/2211 GLENRIDGE AVENUE.
Sponsors: Kathy Lantry
Indexes: Ward - 7, Windows
Code sections:
Attachments: 1. 2209-2211 Glenridge Ave.appeal.6-1-12, 2. 2209-2211 Glenridge Ave.Fry Ltr 6-18-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/12/2012	1	Legislative Hearings	Referred	

Appeal of Greg Fry to an Egress Window Non-Compliance Determination at 2209/2211 GLENRIDGE AVENUE.

Windows

June 1, 2012

David Nelson

No hearing necessary.

Unclear as to why noncompliance determination was issued.

Yes, 2 inches for listed windows.

WHEREAS, in the matter of the Appeal of Greg Fry to an Egress Window Non-Compliance Determination at 2209/2211 GLENRIDGE AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of twelve double hung replacement egress bedroom windows measuring 22 inches high by 33 inches wide for Units 2209 and 2211; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.