



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-132

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 5/16/2012

Title: Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1025 Margaret.appeal.4-10-12, 2. 1025 Margaret St.Kummer 4-19-12.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 5/18/2012 | 2 | Mayor's Office | Signed | |
| 5/16/2012 | 2 | City Council | Adopted | Pass |
| 4/17/2012 | 1 | Legislative Hearings | Referred | |

Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET.

Window is compliant width and 2" short on height

April 2, 2012

James Thomas

No hearing necessary.

Yes, 2 inches egress opening height. Note, orders not necessary on windows of these dimensions.

WHEREAS, in the matter of the Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 1025 MARGARET STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.