



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-203

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 7/3/2012

Title: Appeal of Lance Jackels to a Fire Inspection Correction Notice at 2110 PINEHURST AVENUE.

Sponsors: Chris Tolbert

Indexes: Fire C of O Letter, Ward - 3, Windows

Code sections:

Attachments: 1. 2110 Pinehurst.appeal.5-23-12, 2. 2110 Pinehurst Ave.Jackels Ltr 6-11-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Lance Jackels to a Fire Inspection Correction Notice at 2110 PINEHURST AVENUE.

Older home; has received variance in past.

May 3, 2012

Jay Bohan

No hearing necessary.

Yes, 4 inches egress opening width.

WHEREAS, in the matter of the Appeal of Lance Jackels to a Fire Inspection Correction Notice at 2110 PINEHURST AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable width of the egress window in the second floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.