



## Legislation Details (With Text)

**File #:** RLH WP 12-7 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 2/15/2012  
**Title:** Appeal of Bryan Horton, on behalf of Renewal by Andersen, to an Egress Window Non-Compliance Determination at 1389 SCHLETTI STREET.  
**Sponsors:** Amy Brendmoen  
**Indexes:** Ward - 5, Windows  
**Code sections:**  
**Attachments:** 1. 1389 Schletti.appeal.1-12-12.pdf, 2. 1389 Schletti St.Renewal by Andersen Ltr 1-26-12.pdf

Date	Ver.	Action By	Action	Result
2/21/2012	2	Mayor's Office	Signed	
2/15/2012	2	City Council	Adopted	Pass
1/24/2012	1	Legislative Hearings	Referred	

Appeal of Bryan Horton, on behalf of Renewal by Andersen, to an Egress Window Non-Compliance Determination at 1389 SCHLETTI STREET.

Appealing 2 replacement windows that will not comply w/St. Paul egress policy. Measurements for existing window is included. There will also be 1 window in another bedroom that is an equivalency to the St. Paul policy. Please approve.

January 10, 2012

James Hoffman

No hearing necessary.

5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Bryan Horton, on behalf of Renewal by Andersen, to an Egress Window Non-Compliance Determination at 1389 SCHLETTI STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high by 24 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.