



Legislation Details (With Text)

File #: RLH FCO 22- **Version:** 2
27

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 4/20/2022

Title: Appeal of Barry W. Kostyk to a Fire Inspection Correction Notice at 351 HOPE STREET.

Sponsors: Jane L. Prince

Indexes: Fire C of O Letter, Ward - 7

Code sections:

Attachments: 1. 351 Hope St.appeal.3-14-22, 2. 351 Hope St.Laundry Equipment-Removed.pdf, 3. 351 Hope St.Safety Inspection Information.pdf, 4. 351 Hope St.Photos.3-22-22.pdf, 5. 351 Hope St.Photos #2.3-22-22.pdf, 6. 351 Hope St.Kostyk Fire C of O Ltr.3-24-22, 7. 351 Hope St.Kostyk email.4-4-22.pdf, 8. 351 Hope St.Safety Inspectio Photos-Utility Room.pdf, 9. 351 Hope St.Palm Electric Bill.4-1-22.pdf, 10. 351 Hope St.Safety Inspection Storage Emptied.pdf, 11. 351 Hope St.Kostyk Fire C of O Ltr.4-8-22, 12. 351 Hope St.email.4-12-22.pdf

Date	Ver.	Action By	Action	Result
4/21/2022	2	Mayor's Office	Signed	
4/20/2022	2	City Council	Adopted	Pass
4/5/2022	1	Legislative Hearings	Referred	
3/22/2022	1	Legislative Hearings	Laid Over	

Appeal of Barry W. Kostyk to a Fire Inspection Correction Notice at 351 HOPE STREET.

WHEREAS, in the matter of the Appeal of Barry W. Kostyk to a Fire Inspection Correction Notice at 351 Hope Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal pertaining to providing a 1-hour fire separation between the basement and first floor conditioned upon the hard-wired smoke alarm system being maintained, the continued presence of current smoke blocking barriers, such doors and ceiling construction and there being no combustible storage in basement areas which do not have 1-hour fire separation; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.