



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
47

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 6/1/2011

Title: Appeal of Laura Hay to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1979 IVY AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1979 Ivy.appeal.3-28-11.pdf, 2. 1979 Ivy Ave E.Hay Ltr 4-12-11.pdf

Date	Ver.	Action By	Action	Result
6/6/2011	2	Mayor's Office	Signed	
6/1/2011	2	City Council	Adopted	Pass
4/12/2011	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Laura Hay to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1979 IVY AVENUE EAST.

Egress windows

March 21, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of Laura Hay to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1979 IVY AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress bedroom window; now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.