



Legislation Details (With Text)

File #: RLH FCO 11- **Version:** 2
535

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 1/4/2012

Title: Appeal of Xuan Hguyen to a Fire Certificate of Occupancy Correction Notice at 1227 MAGNOLIA AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6

Code sections:

Attachments: 1. 1227 Magnolia.appeal.11-16-11.pdf, 2. 1227 Magnolia Ave E.STAMP Record.11-29-11.pdf, 3. 1227 Magnolia Ave E.Nguyen Ltr 12-19-11.pdf

Date	Ver.	Action By	Action	Result
1/12/2012	2	Mayor's Office	Signed	
1/4/2012	2	City Council	Adopted	Pass
12/13/2011	1	Legislative Hearings	Referred	
12/6/2011	1	Legislative Hearings	Laid Over	

Appeal of Xuan Hguyen to a Fire Certificate of Occupancy Correction Notice at 1227 MAGNOLIA AVENUE EAST.

Attic - SPLC 34.13(i) The attic has proper ventilation, carbon monoxide detector, lighting, outlets, and a legal size casement window. This can be a safe bedroom. Thank you for your consideration.

October 25, 2011

Mike Cassidy

There are no specific measurements in the orders, beyond indicating that 1/2 of the room is not over 7 feet. On the surface, this case may be a candidate for a variance, but more specific information is needed for the hearing.

Also, it looks as if the C of O has been issued and this went to billing. However, the ceiling height is listed as "abated" at the same time that it is being appealed. Please advise on this at hearing.

WHEREAS, in the matter of the Appeal of Xuan Hguyen to a Fire Certificate of Occupancy Correction Notice at 1227 MAGNOLIA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the attic ceiling height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's

recommendation in this matter.