



Legislation Details (With Text)

File #: ALH 10-559 **Version:** 1
Type: Appeal-Legislative Hearing **Status:** Filed
In control: Legislative Hearings
Final action: 12/21/2010

Title: Appeal of Yemane Mebrahtu to a Fire Inspection Correction Notice at 849 OTTO AVENUE.
Sponsors: Dave Thune
Indexes: Fire C of O Letter, Ward - 2, Windows
Code sections:
Attachments: 1. 849 Otto.appeal.12-21-10.pdf, 2. 849 Otto Ave.PC Ltr.12-21-10.pdf

Date	Ver.	Action By	Action	Result
12/21/2010	1	Legislative Hearings		

Appeal of Yemane Mebrahtu to a Fire Inspection Correction Notice at 849 OTTO AVENUE.

It is a townhouse with 11 units. They were built in 1982. They all have the same safety footage and size. 849 is one of them. The windows conditions are good, except they are not as big as required because at the time they were built the requirement was not in affect.

December 15, 2010

No hearing necessary. Recommend variance on egress window dimensions.