



Legislation Details (With Text)

File #: RLH WP 11- 57 **Version:** 3
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 9/21/2011
Title: Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE.
Sponsors: Melvin Carter III
Indexes: Ward - 1, Windows
Code sections:
Attachments: 1. 719 Charles.appeal.8-23-11.pdf, 2. 719 Charles.Hubbuch Ltr 8-22-11.pdf

| Date | Ver. | Action By | Action | Result |
|-----------|------|----------------------|----------|--------|
| 9/26/2011 | 3 | Mayor's Office | Signed | |
| 9/21/2011 | 3 | City Council | Adopted | Pass |
| 8/23/2011 | 2 | Legislative Hearings | Referred | |

Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE.

Request to replace conforming window w/non conf. replacement.

July 19, 2011

Yes, 3 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable width of one double-hung egress bedroom window measuring 28 inches openable height and 17.5 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.