



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
247

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 12/21/2011

Title: Appeal of Ken Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 324 DALY STREET.

Sponsors: Dave Thune

Indexes: Fire C of O Letter, Ward - 2, Windows

Code sections:

Attachments: 1. 324 Daly.appeal.11-18-11.pdf, 2. 324 Daly St.Anderson Ltr 12-5-11.pdf

Date	Ver.	Action By	Action	Result
12/29/2011	2	Mayor's Office	Signed	
12/21/2011	2	City Council	Adopted	Pass
12/6/2011	1	Legislative Hearings	Referred	

Appeal of Ken Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 324 DALY STREET.

(Only egress windows - see attachment)

November 2, 2011

Sean Westenhofer

No hearing necessary.

Yes, 4 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Ken Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 324 DALY STREET , the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in the 2nd floor west and east bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.