



## Legislation Details (With Text)

**File #:** ALH 11-475    **Version:** 1  
**Type:** Appeal-Legislative Hearing    **Status:** Filed  
**In control:** Legislative Hearings  
**Final action:** 4/12/2011  
**Title:** Appeal of Sarah Kinney to a Rescheduled Fire Inspection Correction Notice at 433 HOLLY AVENUE.  
**Sponsors:** Melvin Carter III  
**Indexes:** Fire C of O Letter, Ward - 1, Windows  
**Code sections:**  
**Attachments:** 1. 433 Holly.appeal.4-6-11.pdf, 2. 433 Holly Ave. Ltr 4-12-11.pdf

| Date      | Ver. | Action By            | Action                           | Result |
|-----------|------|----------------------|----------------------------------|--------|
| 4/12/2011 | 1    | Legislative Hearings | Referred Under Master Resolution |        |

Appeal of Sarah Kinney to a Rescheduled Fire Inspection Correction Notice at 433 HOLLY AVENUE.

Window is 22" high, 24" required

March 14, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of

[title]

the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends [recommendation]

now, therefore, be it

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.