



Legislation Details (With Text)

File #: RLH WP 11- 68 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 10/19/2011

Title: Appeal of Renewal by Andersen, on behalf of Joe Briesler, to an Egress Window Non-Compliance Determination at 155 BELVIDERE STREET EAST.

Sponsors: Dave Thune

Indexes: Ward - 2, Windows

Code sections:

Attachments: 1. 155 Belvidere.appeal.9-6-11.pdf, 2. 155 Belvidere St E.Renewal by Andersen Ltr 9-29-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/20/2011	1	Legislative Hearings	Referred	

Appeal of Renewal by Andersen, on behalf of Joe Briesler, to an Egress Window Non-Compliance Determination at 155 BELVIDERE STREET EAST.

We are appealing 1 window replacement that will not comply w/egress policy. The windows will be short in height by 5". The width will be exceeded by 5" and overall glazed area comes out of 6.6 sq ft. Homeowner wants to keep existing operating style. Please approve.

September 1, 2011

Yes, 5 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Renewal by Andersen, on behalf of Joe Briesler, to an Egress Window Non-Compliance Determination at 155 BELVIDERE STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of one double-hung replacement egress bedroom window measuring 19 inches high by 25 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.