



Legislation Details (With Text)

File #: ALH 10-103 **Version:** 1
Type: Appeal-Legislative Hearing **Status:** Filed
In control: Legislative Hearings
Final action: 9/7/2010

Title: Appeal of Ka Bao Lee to the denial of a building permit to replace egress windows for property at 2114 Scenic Place (Ward 7)

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 2114 Scenic Place.Appeal..9-3-10.pdf

Date	Ver.	Action By	Action	Result
9/7/2010	1	Legislative Hearings	Referred Under Master Resolution	

Appeal of Ka Bao Lee to the denial of a building permit to replace egress windows for property at 2114 Scenic Place (Ward 7)

2114 Scenic Place

Appealing the height of window opening: *we would like to keep the same style of windows in order to preserve the house's character; * also our replacement window will exceed the total glazed area by 5.61 sq ft.; * furthermore, we cannot find a casement window which would fit. our width is 40" to the closest casement window width which would fit is 36". This will have a 4" hole which will not be energy efficient.

September 3, 2010 Egress Window Non-Compliance Determination

September 7, 2010

Granted without hearing.

Grant a 5.25-inch variance on the openable height of three double hung replacement egress windows

[Enter the target date for this item to be introduced to Council]