



Legislation Details (With Text)

**File #:** RLH FOW      **Version:** 2  
12-218

**Type:** Resolution LH Fire Ordered      **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 7/3/2012

**Title:** Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 443 BANFIL STREET.

**Sponsors:** Dave Thune

**Indexes:** Fire C of O Letter, Ward - 2, Windows

**Code sections:**

**Attachments:** 1. 443 Banfil St.appeal.5-31-12, 2. 443 Banfil St.Kummer Ltr 6-18-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/12/2012	1	Legislative Hearings	Referred	

Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 443 BANFIL STREET.

Request variance of window due to size.

May 25, 2012

Michael Efferson

No hearing necessary.

Yes, 5 inches egress opening height for all sleeping rooms.

WHEREAS, in the matter of the Appeal of Joseph Kummer to a Fire Inspection Correction Notice at 443 BANFIL STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress bedroom windows in both units; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.