



Legislation Details (With Text)

File #: RLH FCO 14- **Version:** 2
24

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 3/5/2014

Title: Appeal of Todd Anderson to a Correction Notice-Complaint Inspection at 840 BEECH STREET.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7

Code sections:

Attachments: 1. 840 Beech St.appeal.2-6-14, 2. 840 Beech St.Anderson.2-20-14

Date	Ver.	Action By	Action	Result
3/10/2014	2	Mayor's Office	Signed	
3/5/2014	2	City Council	Adopted	Pass
2/18/2014	1	Legislative Hearings	Referred	

Appeal of Todd Anderson to a Correction Notice-Complaint Inspection at 840 BEECH STREET.

The height of the ceiling of the unit is under 7'. The height of the unit is 6'8".

January 30, 2014

Brian Tonnancour

No hearing necessary.

Yes, 4 inches ceiling height.

WHEREAS, in the matter of the Appeal of Todd Anderson to a Correction Notice-Complaint Inspection at 840 BEECH STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the ceiling height requirement in Unit 5; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.