



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-157

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 6/6/2012

Title: Appeal of Al Nadimi to a Fire Inspection Correction Notice at 1744 UNIVERSITY AVENUE WEST.

Sponsors: Russ Stark

Indexes: Correction Order, Fire C of O Letter, Ward - 4

Code sections:

Attachments: 1. 1744 University.appeal.4-30-12, 2. 1744 University Ave W.Nadimi Ltr 5-10-12.pdf

Date	Ver.	Action By	Action	Result
6/11/2012	2	Mayor's Office	Signed	
6/6/2012	2	City Council	Adopted	Pass
5/8/2012	1	Legislative Hearings	Referred	

Appeal of Al Nadimi to a Fire Inspection Correction Notice at 1744 UNIVERSITY AVENUE WEST.

Windows were installed by Community Action in 2003. Their # is 645-6445. Only one wind is little smaller than permitted.

April 11, 2012

Mitchell Imbertson

No hearing necessary.

Yes, 3 inches egress opening height. ORDERS NOT NECESSARY FOR WINDOWS WITH THESE DIMENSIONS.

WHEREAS, in the matter of the Appeal of Al Nadimi to a Fire Inspection Correction Notice at 1744 UNIVERSITY AVENUE WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3-inch variance on the openable height of the egress window in the second floor middle room; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.