



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
114

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 9/7/2011

Title: Appeal of Michael Hafner to a Fire Certificate of Occupancy Correction Notice at 1824 HOYT AVENUE.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 1824 Hoyt.appeal.7-25-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/16/2011	1	Legislative Hearings	Referred	

Appeal of Michael Hafner to a Fire Certificate of Occupancy Correction Notice at 1824 HOYT AVENUE.

Bedroom window - windows not avail.

June 27, 2011

Yes, 7 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Michael Hafner to a Fire Certificate of Occupancy Correction Notice at 1824 HOYT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.