



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
34

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 6/15/2011

Title: Appeal of William Kamb to a Fire Certificate of Occupancy Correction Notice at 401 HOYT AVENUE EAST.

Sponsors: Lee Helgen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 401 Hoyt.appeal.4-28-11.pdf

Date	Ver.	Action By	Action	Result
6/20/2011	2	Mayor's Office	Signed	
6/15/2011	2	City Council	Adopted	Pass
5/17/2011	1	Legislative Hearings	Referred	

Appeal of William Kamb to a Fire Certificate of Occupancy Correction Notice at 401 HOYT AVENUE EAST.

What: escape windows

Why: 401 Hoyt was built as a duplex in 1969. Windows were replaced in 1998 to original window size openings. Windows do not meet current escape window size. A

Attachments: copy of receipt listing permit as part of cost. Permit on copy is underlined in red.

April 19, 2011

Hearing required.

WHEREAS, in the matter of the appeal of William Kamb to a Fire Certificate of Occupancy Correction Notice at 401 HOYT AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the upper floor's northwest and northeast bedrooms; grant 7 inch variance on egress window sill height requirement for the lower floor south and northeast bedroom if a step must be installed for the full width of the egress, deny the appeal on the lower floor south and northeast bedroom egress window dimensions and grant an extension for 90 days to bring those windows into compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.