



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
272

**Type:** Resolution LH Fire Ordered **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 1/18/2012

**Title:** Appeal of Billy Vang to a Fire Certificate of Occupancy Correction Notice at 1733 YORK AVENUE EAST.

**Sponsors:** Dan Bostrom

**Indexes:** Fire C of O Letter, Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1733 York.appeal.12-8-11.pdf, 2. 1733 York Ave.Vang Ltr 12-20-11.pdf

Date	Ver.	Action By	Action	Result
4/18/2012	2	Mayor's Office	Signed	
1/24/2012	2	Mayor's Office	Signed	
1/18/2012	2	City Council	Adopted	Pass
12/20/2011	1	Legislative Hearings	Referred	

Appeal of Billy Vang to a Fire Certificate of Occupancy Correction Notice at 1733 YORK AVENUE EAST.

Bedroom window northeast side

November 7, 2011

James Thomas

No hearing necessary.

Yes, 1 inch egress opening height.

WHEREAS, in the matter of the Appeal of Billy Vang to a Fire Certificate of Occupancy Correction Notice at 1733 YORK AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress window in the northeast side bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.