



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
119

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 9/7/2011

Title: Appeal of Wendy Teeters to a Fire Certificate of Occupancy Inspection Correction Notice at 603 VAN BUREN AVENUE.

Sponsors: Melvin Carter III

Indexes: Fire C of O Letter, Ward - 1, Windows

Code sections:

Attachments: 1. 603 Van Buren.appeal.8-2-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/9/2011	1	Legislative Hearings	Referred	

Appeal of Wendy Teeters to a Fire Certificate of Occupancy Inspection Correction Notice at 603 VAN BUREN AVENUE.

2 side by side windows 18 H x 23 W

July 14, 2011

Yes, 6 inches in egress window opening height.

WHEREAS, in the matter of the Appeal of Wendy Teeters to a Fire Certificate of Occupancy Inspection Correction Notice at 603 VAN BUREN AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of the double hung window in the bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.