

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: ALH 10-473 Version: 2

Type: Appeal-Legislative Hearing Status: Archived

In control: City Council

Final action: 2/2/2011

Title: Appeal of Gaylen Melby to a Certificate of Occupancy Re-inspection Deficiency List at 803 SNELLING

AVENUE NORTH.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4

Code sections:

Attachments: 1. 803 Snelling.appeal. 12-14-10.pdf, 2. 803 Snelling Ave.C of O Order.12-20-10.pdf, 3. 803 Snelling

Ave.PC ltr.12-21-10.pdf, 4. 803 Snelling Ave.PC ltr.1-19-11.pdf, 5. 803 Snelling Ave.Letter.pdf, 6. 803

Snelling Ave N.Lease Form.1-4-11.pdf

Date	Ver.	Action By	Action	Result
2/2/2011	2	City Council	Granted with Conditions	Pass
12/21/2010	1	Legislative Hearings		
12/14/2010	1	Legislative Hearings	Laid Over	

Appeal of Gaylen Melby to a Certificate of Occupancy Re-inspection Deficiency List at 803 SNELLING AVENUE NORTH.

We owned this duplex bldg over 30 years. We believe it is a Group R occupancy with a total of 8 occupants in the bldg. This is the first inspection that we are aware has been conducted during that time. This building has bedrooms that are equipped with single cylinder deadbolts locks that are operable from inside without the use of keys or special tools. A Fire Inspection Correction Notice dated November 9, 2010 lists a deficiency No. 5 that references as follows: "room doors MSFC 1003.3.1.8-remove unapproved locks from unit doors. The door must be openable from the inside without the use of keys or special knowledge or effort. Remove illegal locks". I cannot locate the code that referenced that.

November 24, 2010 November 9, 2010