



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
13-13

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 10/16/2013

Title: Appeal of Gary Binns to a Correction Notice - Foster Care Inspection at 703 FULLER AVENUE.

Sponsors: Nathaniel Khaliq

Indexes: Ward - 1, Windows

Code sections:

Attachments: 1. 703 Fuller Avenue.appeal.9-23-13, 2. 703 Fuller Ave.Binns Ltr 10-2-13

Date	Ver.	Action By	Action	Result
10/24/2013	2	Mayor's Office	Signed	
10/16/2013	2	City Council	Adopted	Pass
10/1/2013	1	Legislative Hearings	Referred	

Appeal of Gary Binns to a Correction Notice - Foster Care Inspection at 703 FULLER AVENUE.

Inspection from fire inspector. We are appealing the upper bedroom windows. The windows are 22" x 28" wide and there are two of them. Home was built in 1955 regular windows.

September 20, 2013

James Perucca

No hearing necessary.

Yes, 2 inches egress opening height for upper level bedroom.

WHEREAS, in the matter of Appeal of Gary Binns to a Correction Notice - Foster Care Inspection at 703 FULLER AVENUE the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in the upper level bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.