



Legislation Details (With Text)

File #: RLH WP 11- 65 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 10/19/2011

Title: Appeal of The Home Depot At-Home Services, on behalf of Robin Fate, to an Egress Window Non-Compliance Determination at 1191 FAIRMOUNT AVENUE.

Sponsors: Dave Thune

Indexes: Ward - 2, Windows

Code sections:

Attachments: 1. 1191 Fairmount.appeal.8-26-11.pdf, 2. 1191 Fairmount Ave.HOme Depot Ltr 9-29-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/13/2011	1	Legislative Hearings	Referred	

Appeal of The Home Depot At-Home Services, on behalf of Robin Fate, to an Egress Window Non-Compliance Determination at 1191 FAIRMOUNT AVENUE.

(Nothing noted)

August 24, 2011

Yes, 5 inches in opening height.

WHEREAS, in the matter of the Appeal of The Home Depot At-Home Services, on behalf of Robin Fate, to an Egress Window Non-Compliance Determination at 1191 FAIRMOUNT AVENUE; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high x 24.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.