

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH WP 12-6 Version: 2

Type: Resolution LH Window Permit Status: Passed

In control: City Council

Final action: 2/1/2012

Title: Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-

Compliance Determination at 731 HOYT AVENUE.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 731 Hoyt.appeal.1-10-12.pdf, 2. 731 Hoyt Ave.Public Health Ltr 1-18-12.pdf

Date	Ver.	Action By	Action	Result
2/7/2012	2	Mayor's Office	Signed	
2/1/2012	2	City Council	Adopted	Pass
1/17/2012	1	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 731 HOYT AVENUE.

Request for egress window non-compliance determination.

January 10, 2012

No hearing necessary.

Yes, 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, on behalf of Ramsey County Public Health, to an Egress Window Non-Compliance Determination at 731 HOYT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of one double hung replacement egress window measuring 19.93 inches high by 31.2 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.