



## Legislation Details (With Text)

**File #:** RLH WP 12-5 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 2/1/2012  
**Title:** Appeal of Derek Tanberg, on behalf of The Window Store Home Improvements, Inc., to an Egress Window Non-Compliance Determination at 1046 STINSON STREET.  
**Sponsors:** Melvin Carter III  
**Indexes:** Ward - 1, Windows  
**Code sections:**  
**Attachments:** 1. 1046 Stinson.appeal.1-6-11.pdf, 2. 1046 Stinson St.Window Store Ltr 1-18-12.pdf

Date	Ver.	Action By	Action	Result
2/7/2012	2	Mayor's Office	Signed	
2/1/2012	2	City Council	Adopted	Pass
1/17/2012	1	Legislative Hearings	Referred	

Appeal of Derek Tanberg, on behalf of The Window Store Home Improvements, Inc., to an Egress Window Non-Compliance Determination at 1046 STINSON STREET.

These windows just miss on qualifying for egress. Julie Rohlik doesn't want 2 windows in the house to miss match the rest of her new windows.

January 6, 2012

J. Hoffman

No hearing necessary.

Yes, 2 inches egress opening height.

WHEREAS, in the matter of the Appeal of Derek Tanberg, on behalf of The Window Store Home Improvements, Inc., to an Egress Window Non-Compliance Determination at 1046 STINSON STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 22 inches high by 23.34 inches wide.; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.