



Legislation Details (With Text)

File #: RLH FOW **Version:** 2
12-201

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 7/3/2012

Title: Appeal of Todd Schneider to a Fire Certificate of Occupancy Inspection Correction Notice at 1350 HEWITT AVENUE.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 1350 Hewitt.appeal.5-23-12.pdf, 2. 1350 Hewitt Ave.Schneider Ltr 6-13-12.pdf

Date	Ver.	Action By	Action	Result
7/9/2012	2	Mayor's Office	Signed	
7/3/2012	2	City Council	Adopted	Pass
6/5/2012	1	Legislative Hearings	Referred	

Appeal of Todd Schneider to a Fire Certificate of Occupancy Inspection Correction Notice at 1350 HEWITT AVENUE.

The windows and trim are made from nice hardwood that has been maintained to the original style and function. I have worked very hard and spent money on retaining the character of this property. Replacing of these windows would destroy that character.

May 16, 2012

Sebastian Migdal

No hearing necessary.

Yes, upper level bedroom 1 - 4 inches egress opening height, upper level bedroom 2 - 3 inches egress opening height and upper level bedroom 3 - 5 inches egress opening height.

WHEREAS, in the matter of the Appeal of Todd Schneider to a Fire Certificate of Occupancy Inspection Correction Notice at 1350 HEWITT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in the upper level bedroom 1, grant a 3-inch variance on the openable height of the egress window in the upper level bedroom 2, and grant a 5-inch variance on the openable height of the egress window in the upper level bedroom 3; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

