



Legislation Details (With Text)

File #: RLH WP 12- 46 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 6/20/2012
Title: Appeal of Allen Reistad, on behalf of Ana Baumgart, to an Egress Window Non-Compliance Determination at 1513 MCAFEE STREET.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 1513 Mcafee.appeal.5-4-12.pdf, 2. 1513 Mcafee St.Reistad Ltr 5-21-12.pdf

Date	Ver.	Action By	Action	Result
6/25/2012	2	Mayor's Office	Signed	
6/20/2012	2	City Council	Adopted	Pass
5/15/2012	1	Legislative Hearings	Referred	

Appeal of Allen Reistad, on behalf of Ana Baumgart, to an Egress Window Non-Compliance Determination at 1513 MCAFEE STREET.

Only egress windows

May 4, 2012

David Nelson

No hearing necessary.

Yes, 1 inch egress opening width.

WHEREAS, in the matter of the Appeal of Allen Reistad, on behalf of Ana Baumgart, to an Egress Window Non-Compliance Determination at 1513 MCAFEE STREET; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council Grant a 1-inch variance on the openable width of one casement replacement egress bedroom window measuring 37 inches high by 19.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.