



Legislation Details (With Text)

File #: RLH FCO 12- **Version:** 2
367

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 8/15/2012

Title: Appeal of John Mezzenga to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 677 SUMMIT AVENUE.

Sponsors: Melvin Carter III

Indexes: Fire C of O Letter, Ward - 1

Code sections:

Attachments: 1. 677 Summit Ave.appeal.6-01-12, 2. 677 Summit Ave.Mezzenga Ltr 6-21-12.pdf, 3. 677 Summit Ave.Mezzenga Ltr 7-11-12.pdf

Date	Ver.	Action By	Action	Result
8/22/2012	2	Mayor's Office	Signed	
8/15/2012	2	City Council	Adopted	Pass
8/1/2012	2	City Council	Continue Public Hearing	Pass
7/10/2012	1	Legislative Hearings	Referred	
6/19/2012	1	Legislative Hearings	Laid Over	

Appeal of John Mezzenga to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 677 SUMMIT AVENUE.

#4 - Existing windows size have passed previous C of O inspections. These are the original windows and have not been altered. Cannot afford to replace.

#5 - Currently saving money to demolish garage and build new structure. Historic Preservation Commission has strict building guidelines in this area that will require additional funds.

May 21, 2012

Michael Efferson

Hearing on the balance of the appeal.

Yes, 2nd floor - 7 inches egress opening height.

WHEREAS, in the matter of the Appeal of John Mezzenga to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 677 SUMMIT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant the appeal on the garage but will need to bring it into compliance in the next reinspection cycle. The garage will be reassessed from time to time to ensure that it doesn't become a dangerous structure. If the garage becomes a dangerous structure, enforcement action will be taken; grant a 7-inch variance on the openable height of the egress

window in the second floor bedroom; and deny a variance on the egress window in the third floor bedroom and grant an extension for 90 days for compliance; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.