



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-95, **Version:** 2

Appeal of Mark J. Pierce, MP Systems Inc., to an Egress Window Non-Compliance Determination at 1338 REANEY AVENUE EAST.

Two windows in home due to size and permit issue.

Yes, 1 inch in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Mark J. Pierce, MP Systems Inc., to an Egress Window Non-Compliance Determination at 1338 REANEY AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width of two casement replacement egress bedroom windows measuring at 55 inches high by 19 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.